


FIRE SAFETY CERTIFICATE

RC No. HGWMC/DFO/E-150067/SCAL/2025, Dated: 02-12-2025.

Certified that the EKASILA EDUCATION SOCIETY at H.No: 1-7-1003, Hunter Road, Hanumakonda comprised of Ground, First, Second and Third Floors owned/ occupied by **WARANGAL PUBLIC SCHOOL**, Hunter Road, Hanumakonda have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by the officers concerned of Fire Service on 02-12-2025 (Date of Inspection) in the presence of Smt Yellambatla Gouri Kalyani, Principal, Warangal Public School (name and addresses of the Manager/ Secretary or his representative) and that the building/premises is fit for occupancy upto classes X with effect from 02-12-2025 for a period of **ONE YEAR** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Annual Fire Safety Inspection conducted and found satisfactory

Issued on 02-12-2025 at Hanumakonda


 S. Shankar Lingam
 District Fire Officer, 02/12/2025
 Fire Prevention Wing

Name : (Municipal Corporation, Warangal)

S. SHANKAR LINGAM.
DISTRICT FIRE OFFICER.
G WMC, WARANGAL.

To

The Principal,
 Warangal Public School,
 Hunter Road, Hanumakonda.

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to (reasons to be recorded).

(Name and designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

11/12/2025
11/12/2025
11/12/2025

9/12/2025
 Secretary & Correspondent
WARANGAL PUBLIC SCHOOL
 HUNTER ROAD, HANUMAKONDA, WARANGAL


 Principal
WARANGAL PUBLIC SCHOOL
 Hunter Road, Hanumakonda, TS

GREATER WARANGAL MUNICIPAL CORPORATION

From
 The Commissioner
 Greater Warangal Municipal Corporation
 Warangal



To
 Vodithala Lakshmikantha Rao
 H.No.1-108, Singapur,
 Huzurabad, Karimnagar.

RC.No. HO/GWMC/DFO/E-150067/SCHL/2025,

Date: 02.12.2025

Sub: Greater Warangal Municipal Corporation – Fire Prevention Wing – Renewal of No Objection Certificate for occupancy to the Non-MSB of M/s. Warangal Public School, H.No. 1-7-1041 & 1-7-1042, Hunter Road, Hanumakonda district – Reg.

Ref: 1. RC.No.5041/B2/97,Dt:-12-03-2010 of Director General, A.P. State Disaster Response and Fire Services, A.P Hyderabad.
 2. Application of the Principal Warangal Public School, H.No. 1-7-1041 & 1-7-1042, Hunter Road, Hanumakonda, Dt: 18.11.2025.
 3. Note approval of the Commissioner, GWMC vide file e-150067, Date: 02-12-2025.
 4. Renewal of NOC for occupancy Rc.No.HO/DFO/E-143006/ GWMC/ SCHL/2024, Date: 26.11.2024.

vide reference 2nd cited the principal Warangal Public School submitted an application for requesting to issue Renewal of NOC for occupancy to the M/s Warangal Public School, H.No. 1-7-1041 & 1-7-1042, Hunter Road, Hanumakonda district. Under the powers delegated vide ref. 1st cited, the Officers of Fire Prevention Wing, GWMC Warangal have inspected the premises of above school on 20.11.2025 and submitting the following report.

The management has constructed Ground +3 Upper Floors with a height of 11.50 Mts. for Non-Multi storied educational occupancy (B1), and obtained renewal of NOC for occupancy Vide reference 4th cited.

1. Open Spaces & Gate Width:

3	Sl.No.	Open Spaces	Required as per occupancy NOC	Provided Now	Deficit
a	1	NORTH	3.00 Mts	3.00 Mts	-----
	2	SOUTH (Front)	10.00 Mts	10.00 Mts	-----
	3	EAST	8.00 Mts	8.00 Mts	-----
	4	WEST	4.00 Mts	4.00 Mts	-----
b	Sl.No.	Gate Width (As per NBC 2005)	Required	Provided	Deficit
	1	Entry gate width	4.50 Mts	4.50 Mts	-----
	2	Entry Gate Head Clearance	5.00 Mts	5.00 Mts	-----

2. Floor Wise Details:

Sl. No.	Floor Wise Details				Means of Escape	
	Floor Type	Type of Occupancy	Built Up Area in Sq. Mts	Occupant Load	Required	Provided
1	Ground Floor	Educational (B1)	1466.72	235	4.65 Mts	4.65 Mts
2	First Floor	Educational (B1)	1466.72	225	4.65 Mts	4.65 Mts
3	Second Floor	Educational (B1)	1466.72	225	4.65 Mts	4.65 Mts
4	Third Floor	Educational (B1)	330.30	75	1.50 Mts	4.65 Mts

3. Stair Cases (As per NBC 2005):

Sl. No.	Type of Staircase	No. of Staircases	Width	Floor from	Floor to
1	Internal Staircase1	1 No's	1.15 Mts	Ground	Terrace
2	Internal Staircase2	1 No's	1.70 Mts	Ground	Terrace
3	Internal Staircase3	1 No's	1.80 Mts	Ground	Terrace

4. Travel Distance & Dead end of the corridor:

Sl.No.		Required	Provided	Deficit
1	Farthest point (Most Remote Point) Within a storey or a mezzanine floor to the door to an Exit.	30 Mts	30 Mts	-----
2	The Dead end of the corridor length in exit access. (not exceeding 06 meters for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00 Mts	6.00 Mts	-----

5. Fire Fighting Installations as per Table 7 of NBC 2005:

Sl. No.	Fire Fighting System	Required	Provided
1	Fire Extinguishers	28 No's	28 No's
2	First Aid Hose Reel	7 No's	7 No's
3	Terrace Tank	10,000 Lts	10,000 Lts
4	Terrace Pump/ Booster Pump	450 LPM	450 LPM
5	Down Commer	2 No's	2 No's

The management has remitted fire prevention fee vide GWMC Cash receipt No. 143249 Dated; 19.11.2025 for Rs.10, 000/- (Rupees Ten Thousand only).